
From: Chen, Hornlean
Sent: Tuesday, June 5, 2018 1:36 PM
To: hunta1@guilford.edu
Cc: Munger, Bridget; Raynor, Linda; Godreau, Jessica; Hrebeniuk, Boris
Subject: data request for the NC0241410 Brown Summit School

Hi Mr. Hunt,

Below is the Lead and Copper Violation History for the NC0241410 Brown Summit School

During sampling in 2007, 4 of 5 results exceeded the action level for copper. The system was informed that an Optimal Corrosion Control Treatment (OCCT) recommendation, including Water Quality Parameters (WQP) and source water sampling results, is due 3/29/2008.

A notice of violation for failure to submit the OCCT recommendation was issued to the system on 2/25/2009 with public notification due in 30 days.

A notice of violation for failure to complete the required public notification for OCCT violation was issued to the system on 6/4/2009.

An administrative penalty for the OCCT violation was issued to the system on 6/17/2009 and the penalty was paid and received on 4/23/2010.

The OCCT recommendation was received from system on 4/19/2011 and the system is currently in compliance with the lead and copper rules.

Hornlean Chen
Assistant Branch Head - Compliance Services Branch
Public Water Supply Section/Division of Water Resources
North Carolina Department of Environmental Quality

919.707-9068 office
hornlean.chen@ncdenr.gov

1634 Mail Service Center
Raleigh, NC 27699-1634



Email correspondence to and from this address is subject to the North Carolina Public Records Law and may be disclosed to third parties.

